

VOC Content Test Certificate

Thursday, 6th September 2018

Supplier: Hychem International Pty Ltd (1/30 Bluett Drive, Smeaton Grange, NSW, 2567).

Sample Description: Velosit[®] SC 241

Date Tested: September 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p>	<p>Velosit[®] SC 241</p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p>2 grams per Litre as VOC content</p>
<p><i>We hereby certify Velosit[®] SC 241 is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180899V